



STANDARD AS SHOWN		OPTION-1		OPTION-2	
IN	OUT	IN	OUT	IN	OUT
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

HEADER SIZE
<input type="checkbox"/> 0-300 USGPM Ø3"
<input type="checkbox"/> 301-500 USGPM Ø4"
<input type="checkbox"/> 501-1100 USGPM Ø6"

CONTROL PANEL POSITION	
ITEM 9	<input type="checkbox"/> 0°
	<input type="checkbox"/> 90°
	<input type="checkbox"/> 180°
	<input type="checkbox"/> 270°
	<input type="checkbox"/> WALL MOUNTED

### DISCHARGE OPTIONS

	PUMP No.1	PUMP No.2	PUMP No.3
<b>A</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>STANDARD</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### SUCTION OPTIONS

	PUMP No.1	PUMP No.2	PUMP No.3
<b>F</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>E</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>STANDARD</b>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

- T-HC-\_\_\_\_\_
- T-HC-HT-\_\_\_\_\_


- HYDRO-PNEUMATIC TANK**
- NOT INCLUDED
  - INCLUDED
  - MOUNTED
  - SHIP LOOSE

<b>FLO FAB</b> <b>AQUA PROFAB</b>		ENGINEER / INGENIEUR CUSTOMER / CLIENT
<b>FLO FAB TRIPLEX CONSTANT PRESSURE SYSTEMS</b> SERIES "HC"		DATE / DATE APRIL 2007
880 BOULEVARD INDUSTRIEL BOULDER, COLORADO, U.S.A. 303.447.1400 / 303.447.9395		PART LIST N° / LISTE DE MATERIEL, N°
M. LYMBURNER		DRAWING N° / N° DESSIN T-HC-1000_2000 SUBMITTAL
SCALE / ÉCHELLE N/A		REV 0

NO	QTY	DESCRIPTION	SIZE	PART NUMBER
1	1	PUMP 1		
2	1	PUMP 2		
3	1	PUMP 3		
5	1	M1 MOTOR		
6	1	M2 MOTOR		
7	1	M3 MOTOR		
9	1	PANEL CONTROL		
14		NO. 1 TRIPLE DUTY VALVE		
15		NO. 2 TRIPLE DUTY VALVE		
16		NO.3 TRIPLE DUTY VALVE		
18		NO. 1 SUCTION DIFFUSER (WITH STRAINER)		
19		NO. 2 SUCTION DIFFUSER (WITH STRAINER)		
20		NO. 3 SUCTION DIFFUSER (WITH STRAINER)		
22		NO. 1 Y-STRAINER		
23		NO. 2 Y-STRAINER		
24		NO. 3 Y-STRAINER		
30		NO. 1 DISCHARGE BUTTERFLY VALVE		
31		NO. 2 DISCHARGE BUTTERFLY VALVE		
32		NO. 3 DISCHARGE BUTTERFLY VALVE		
34		NO. 1 SUCTION BUTTERFLY VALVE		
35		NO. 2 SUCTION BUTTERFLY VALVE		
36		NO. 3 SUCTION BUTTERFLY VALVE		
38		NO. 1 DISCHARGE CHECK VALVE		
39		NO. 2 DISCHARGE CHECK VALVE		
40		NO. 3 DISCHARGE CHECK VALVE		

<input type="checkbox"/>	T-HC-_____
<input type="checkbox"/>	T-HC-HT-_____

PAGE 1/2

TITLE / TITRE		FLO FAB - TRIPLEX "HC" SERIES 1000/2000	
		MATERIAL LIST	
 <b>FLO FAB</b> <b>AQUA PROFAB</b>		PROJECT / PROJET	
860 BOULEVARD INDUSTRIEL BOIS-DES-FILION, QC J6Z 4V7, (450) 621-2995		CUSTOMER / CLIENT	
DRAWING N° / N° DESSIN	DATE / DATE	MAY 2007	
DRAWN BY / DESSINATEUR	SCALE / ÉCHELLE	PART LIST N° / LISTE DE MATÉRIEL N°	REV
M. LYMBURNER	N / A		0

REV	DESCRIPTION	DATE	INIT.

NO	QTY	DESCRIPTION	SIZE	PART NUMBER
46	1	SUCTION HEADER SIZE AND MATERIAL		
47	1	DISCHARGE HEADER SIZE AND MATERIAL		
51	1	SUCTION PRESSURE GAUGE		
52	1	DISCHARGE PRESSURE GAUGE		
53	2	PET COCKS		
57		DISCHARGE EXPANSION TANK (CPS SYSTEM)		
65		SUCTION FLEXIBLE		
66		DISCHARGE FLEXIBLE		
68	1	P1 TEMPERATURE RELIEF CONTROL VALVE		
69	1	P2 TEMPERATURE RELIEF CONTROL VALVE		
70	1	P3 TEMPERATURE RELIEF CONTROL VALVE		
86	1	STEEL FABRICATED BASEPLATE		

<input type="checkbox"/>	T-HC-_____
<input type="checkbox"/>	T-HC-HT-_____

PAGES 2/2

TITLE / TITRE <b>FLO FAB - TRIPLEX "HC" SERIES 1000/2000</b> <b>MATERIAL LIST</b>	
	PROJECT / PROJET
860 BOULEVARD INDUSTRIEL BOIS-DES-FILION, QC J6Z 4V7, (450) 621-2995	CUSTOMER / CLIENT
	DRAWING N° / N° DESSIN DATE / DATE MAY 2007
DRAWN BY / DESSINATEUR M. LYMBURNER	SCALE / ÉCHELLE N / A
PART LIST N° / LISTE DE MATÉRIEL N°	
REV 0	

REV	DESCRIPTION	DATE	INIT.